VIRON INTERNATIONAL CORP.
OWOSSO, MICHIGAN TEMPLE, TEXAS
989-723-8255
989-723-8417 FAX EMAIL: vironinfo@vironintl.com
ENVIRON MENTAL CONTROL SYSTEMS

USER	
REP.	
JOB NO.	
DATE	SHEET OF
DRAWN BY	

STANDARD DIAMETERS "A" = 4"-120"



NOTES:
1. ☐ 304L ☐ 316L SST MATERIAL WITH 2B FINISH.
2. 304 SST ANGLE RINGS DRILLED
3. HALAR COATING, INTERIOR ONLY.
4. TIG WELDS ONLY.
5. FUSION WELDS ON ALL LONGITUDINAL S
6. "G" REQUIRES A 9" MIN. LENG
7. D & E REQUIRES 3" MIN. LENGTH.

STATIC PRESSURE
☐ -6"WG ☐ -10"WG
OTHER: _____

PART NUMBER	DESCRIPTION									GA	QTY	REMARKS
	A	B	C	D	E	F	G	I	M			

SSTEELCOAT® REDUCER w/45° TAP